

Summary Report

FirstRate Report



Rating 7.5 stars



Energy	Total	141.2 MJ/m2
	Heating	116.7 MJ/m2
	Cooling	24.5 MJ/m2
Area Corrected Energy	Total	112.2 MJ/m2
	Heating	92.8 MJ/m2
	Cooling	19.5 MJ/m2

Areas	NCFA	81.6 m2
	NUCFA	11.5 m2

Climate 66 Ballarat Aerodrome

Site Exposure suburban

Client Name Eco Villages Worldwide

Rated Address Epod 3B

Accredited Rater Kristy Gunn VIC 09/021

Date 23/06/2009

Reference EVW03 0003B

Comment

AWS STANDARD GLAZING U2.9 SHGC 0.44 AWS DOOR GLAZING U3.2 SHGC 0.57

This rating only applies to the floor plan, construction details, orientation and climate as submitted and included in the attached stamped plans.

Changes to any of these could affect the rating.

